



Greater  
Hume  
Council



# Pollution Incident Response Management Plan

## Henty Sewage Treatment Plant

[greaterhume.nsw.gov.au](http://greaterhume.nsw.gov.au)

Rev No	Date	Revision Details	Author	Reviewer	Approver
3	26 June 2024	First Edition, Revision 3	Manager Water and Waste Water	Director Engineering	General Manager

Prepared By:  
Greater Hume Council  
With Assistance From  
Daryl McGregor Pty Ltd, Engineering Consultants  
Strategies for a Water Efficient Future

## Document Status and Release Information

### Daryl McGregor Pty Ltd

ABN 63 119 722 093






641 Macauley Street  
Albury NSW 2640 Australia  
T: 61 2 6041 6403  
F: 61 2 6041 6403  
M: 0417 271 618  
E: [darylm@bigpond.com](mailto:darylm@bigpond.com)

Client:	Greater Hume Council
Project No:	1057/13C
Document Title:	Pollution Incident Response Management Plan – Henty STP

## Copyright/ Disclaimer

This document is and shall remain the property of Daryl McGregor Pty Ltd. The document may only be used for the purposes for which it was commissioned and in accordance with the Terms of Engagement for the commission. Unauthorised use of this document in any form whatsoever is prohibited.

## Document Status

Rev No.	Prepared By		Reviewer		Approved for issue	
	Name	Date	Name	Signature	Signature	Date
0 - Draft	D. McGregor	11/07/13	D. McGregor			12/07/13
1 - Final	D. McGregor	18/07/13	D. McGregor			18/07/13
2 - Revised	T. Plunkett	22/09/16	T. Plunkett			29/09/16
3 - Revised	B. Falconer	26/06/2024	B. Falconer			26/06/2024

## Executive Summary

This Pollution Incident Response Management Plan (PIRMP) has been prepared in accordance with the *Protection of the Environment Legislation Amendment Act 2011 (POELA Act)* and reflects the requirements specified in the Environment Protection Authority's (EPA's) *Guidelines: Preparation of Pollution Incident Response Management Plans, March 2012*.

It identifies the hazards to the environment associated with the Henty Sewage Treatment Plant and its operations; provides pre-emptive measures to reduce such hazards, details the essential contact and communication mechanisms in the case of an incident.

The PIRMP also details:

- procedures for notifying a pollution incident to relevant persons
- actions to be taken to reduce and/or control pollution; and
- procedures for co-ordinating those notified and any action taken in combating the pollution.

Maps and information about the training of staff and testing of the plan are also included.

The structure of the plan is in accordance with the requirements set out in part 5.7A of the POEO Act and the Protection of the Environment (General) Amendment (Pollution Incident Response Management Plans).

This plan will also be, utilised by Greater Hume Council as an effective review and planning tool in managing Council's Licence obligations and to enhance Council's environmental management.

It will complement Council's Environmental Management Plans and Emergency Response Plans.

This page is intentionally left blank.



## Table of Contents

1.0	Introduction .....	1
1.1	Purpose of Report .....	1
1.2	Definition of a Pollution Incident.....	1
1.3	Henty STP's EPA Licence .....	1
1.4	Treatment Plant Details .....	2
2.0	Descriptions of Hazards to Human Health or the Environment and Likelihood of Occurrence ..	4
2.1	Potential Pollution Incidents.....	4
2.2	Likelihood of Occurrence .....	4
3.0	Pre-Emptive Actions to Minimise Risk to Human Health or the Environment.....	9
4.0	Inventory of Pollutants and Details of Storage Locations.....	12
5.0	Description of Safety Equipment or Other Devices Used to Minimise Risk and To Control a Pollution Incident .....	13
6.0	Contact Details.....	14
6.1	Definition of Pollution Incident.....	14
6.2	Notification of Pollution Incident.....	14
6.3	List of Those Authorised To Notify Relevant Authorities Under Section 148 Of POEO Act .	17
7.0	Communication with Neighbours and Local Community.....	18
8.0	Arrangements to Minimise Risk of Harm to Persons on the Premises Should an Incident Occur .....	20
9.0	Actions to be Taken During or Immediately After a Pollution Incident, Including Early Warnings, Updates and Actions to be Undertaken by the Media.....	21
10.0	Staff Training.....	22
11.0	Making Plans Available .....	23
12.0	Testing Plans Once Every 12 Months .....	24
13.0	Appendices .....	25
13.1	Appendix A: Risk Assessment Matrix.....	25
13.2	Appendix B: Pollution Incident Reporting Form.....	28
13.4	Appendix C: PIRMP Testing and Update Register Update Register.....	30
13.5	Appendix D: Staff Training Register.....	31
13.6	Appendix E: Site Plan .....	32

This page is intentionally left blank.

## 1.0 Introduction

### 1.1 Purpose of Report

Changes to the Protection of the Environment Operations Act 1997 (POEO Act) came into force on 29 February 2012. The changes effectively require licence holders to develop, implement and formally test Pollution Incident Response Management Plans (PIRMPs) for each of their licensed activities.

The requirements are set out in part 5.7A of the POEO Act and details are contained in the Protection of the Environment (General) Amendment (Pollution Incident Response Management Plans). This PIRMP has been prepared in accordance with those requirements.

Greater Hume Council intends not only to implement this PIRMP for Henty Sewage Treatment Plant (Henty STP), but also to use it as an effective review and planning tool in managing Council's licence obligations and to enhance Council's environmental management.

It will complement Council's Environmental Management Plans and Emergency Response Plans.

### 1.2 Definition of a Pollution Incident

A pollution incident is required to be notified if there is a risk of 'material harm to the environment', which is defined in section 147 of the POEO Act 1997:

- a) *harm to the environment is material if:*
  - i) *it involves actual or potential harm to the health or safety of human beings or to ecosystems that is not trivial, or*
  - ii) *it results in actual or potential loss or property damage of an amount, or amounts in aggregate, exceeding \$10,000 (or such other amount as is prescribed by the regulations), and*
- b) *loss includes the reasonable costs and expenses that would be incurred in taking all reasonable and practicable measures to prevent, mitigate or make good harm to the environment.*

### 1.3 Henty STP's EPA Licence

The Henty Sewage Treatment Plant operates under EPA Licence No. 3726. The licence authorises Council as the operator and licence holder to discharge up to 250 KL/day of treated effluent.

The treatment plant provides tertiary treatment via a pasveer channel which provides extended aeration (activated sludge) treatment; and effluent is reused at the Henty Public School, St Pauls Lutheran School, Henty Showgrounds, Henty Memorial Park and Henty Bicentennial Park.

## 1.4 Treatment Plant Details

Henty Sewerage Scheme was constructed in 1971. It services 489 residential assessments, 74 non-residential assessments and covers an area of 91ha within the Henty urban area. The sewerage scheme comprises approximately 10m of rising mains, 12.1km of reticulation pipelines, one sewage pump station and the Henty Sewage Treatment Plant.

The Henty STP consists of a pasveer channel, two sludge lagoons and a tertiary effluent pond. The pasveer channel capacity is a 1,000 EP (1000 persons channel).

The pasveer channel provides activated sludge treatment process of the raw sewage influent operating in the intermittent extended aeration mode. As an extended aeration system with a sludge age in excess of 20 days it produces an aerobically digested sludge as well as a high quality effluent.

Effluent is currently held in a 30 day effluent pond which provides tertiary treatment (Aerobic process) sunlight (UV) disinfection and further settlement of solids. Effluent is discharged under licence to a 30ML reuse storage dam with overflow to adjacent Crown land for disposal via evaporation.

### Henty Sewerage Reuse Scheme


The Henty Sewerage Reuse Scheme was constructed in 1999. It comprises approximately 3.2km of reuse supply mains and one reuse treatment plant located at the Henty STP. It pumps effluent from a 30ML storage dam through a series of disc filters then is chemically dosed for PH correction and disinfection. It is then pumped to five locations for irrigation which are Henty Recreation Ground (football oval), Memorial Park, Bicentennial Park, Henty Primary Public School (sports field) and St Paul's Primary School (sports field).



A schematic of the Henty Treatment System is shown in Figure 1 on page 3.



Figure 1: Henty STP Flowchart



## 2.0 Descriptions of Hazards to Human Health or the Environment and Likelihood of Occurrence

### 2.1 Potential Pollution Incidents

The potential main hazards to human health or the environment – i.e. 'Pollution Incidents' - associated with the activities undertaken at this site include the following:

- Wet weather overflow from the reticulation system **during wet weather**
- Dry weather overflow from the reticulation system **during dry weather**
- Wet weather bypass at the Henty STP which may occur when untreated sewage bypasses the sewage treatment process and discharges to the environment **during wet weather**
- Dry weather bypass at the Henty STP which may when untreated sewage bypasses the sewage treatment process and discharges to the environment **during dry weather**
- Pond failure at the Henty STP
- Mechanical failure at the Henty STP resulting in discharge of untreated sewage
- Mechanical failure at the Henty STP resulting in offensive odour from the premises
- Inadequate chemical storage and/or chemical handling
- Acts of vandalism or target of terrorist activity at the Henty STP
- Discharge pipeline breakage
- Exceed EPA discharge limits; or
- Significant adverse environmental impact resulting from irrigation in utilisation areas.

Other potential hazards include:

- Inappropriate sludge handling and/or disposal
- Structural failure of treatment units resulting in release of untreated or partially treated sewage
- Failure of pump(s) resulting in release of sewage or effluent to the environment
- Uncontrolled release of gases or odours;
- Flooding of process units or storage ponds resulting in release of pollutants to the environment
- Illegal dumping of pollutants into the sewerage system
- Staff coming into contact with raw sewage or partially treated sewage
- Public coming into contact with raw sewage or treated effluent.

### 2.2 Likelihood of Occurrence

Each of the hazards is listed in Table 1 on page five and their likelihood of occurrence defined. The Risk Assessment Matrix used to derive the likelihood of occurrence is appended in *Appendix A*.

Table 1: Pollution Incident Classification, Risk Assessment and Contributing Factors

Risk	Description	Consequence	Likelihood	Contributing factors	Overall Risk Rating
<b>Overflows and Bypasses</b>					
	Wet weather overflow from the reticulation system during wet weather.	Moderate	Rare	Prolonged periods of heavy rain, heavy infiltration of stormwater into the sewer network.	Low
	Dry weather overflow from the reticulation system during dry weather.	Moderate	Rare	Mechanical failure of plant and equipment. Infrastructure failure.	Low
	Wet weather bypass at the Henty STP when untreated sewage bypasses the sewage treatment process and discharges to the environment during wet weather.	Moderate	Unlikely	Prolonged periods of heavy rain, lack of maintenance and/or a mechanical failure of plant and equipment.	Medium
	Dry weather bypass at the Henty STP when untreated sewage bypasses the sewage treatment process and discharges to the environment during dry weather.	Moderate	Unlikely	Lack of infrastructure maintenance and/or a mechanical failure of plant and equipment.	Medium
	Pond failure at the Henty STP.	Minor	Rare	Prolonged periods of heavy rain, lack of pond and site maintenance and/or a mechanical failure of plant and equipment.	Low
	Mechanical failure at the Henty STP results in discharge of untreated sewage.	Major	Rare	Fire damage or poor maintenance of plant and equipment. Prolonged periods of heavy rain.	Medium
	Flooding of process units or storage ponds resulting in release of pollutants to the environment.	Moderate	Rare	Prolonged periods of heavy rain, lack of pond and site maintenance and/or a mechanical failure of plant and equipment.	Low

Risk	Description	Consequence	Likelihood	Contributing factors	Overall Risk Rating
<b>Odours</b>					
	Mechanical failure at the Henty STP results in offensive odour from the premises.	Moderate	Unlikely	Fire damage or poor maintenance of plant and equipment.	Medium
	Uncontrolled release of gases or odours.	Moderate	Unlikely	Poor maintenance; process and/or equipment failure.	Medium
<b>Chemicals</b>					
	Inadequate chemical storage.	Moderate	Rare	Human error. Chemical fire accelerated by high winds, dry weather, prolonged periods of high temperatures and low humidity.	Low
<b>Vandalism</b>					
	Acts of vandalism or terrorist activity at the Henty STP.	Major	Rare	Increased risk during hours of closure.	Medium
<b>Pipe failure</b>					
	Discharge pipeline breakage.	Moderate	Rare	Poor maintenance of plant and equipment. Flows exceeding pipe and pump capacity.	Low
<b>Structural failure</b>					
	Structural failure of treatment units resulting in release of untreated or partially treated sewage.	Major	Rare	Poor maintenance or design; overloading of plant; vandalism or other attack on the plant.	Low
	Failure of pump(s) resulting in release of sewage or effluent to the environment.	Moderate	Unlikely	Poor maintenance, electrical failure.	Medium

Risk	Description	Consequence	Likelihood	Contributing factors	Overall Risk Rating
<b>Licence Exceedence</b>					
	Exceed Environment Protection Licence (EPL) discharge limits to the environment.	Minor	Unlikely	Prolonged periods of heavy rain; overloading of plant; mechanical failure of plant and equipment; treatment process failure.	Low
<b>Irrigation Activities</b>					
	Significant adverse environmental impact from irrigation in utilisation areas.	Minor	Unlikely	Human error. Lack of control and/or monitoring. Prolonged periods of heavy rain.	Low
<b>Sludge Handling</b>					
	Inappropriate sludge handling and/or disposal.	Minor	Unlikely	Human error. Prolonged periods of heavy rain.	Low
<b>Trade Waste</b>					
	Illegal dumping of pollutants into the sewerage system.	Major	Rare	Poor implementation of Trade Waste Policy.	Medium
<b>Staff Contact With Pollutants</b>					
	Staff coming into contact with raw sewage or partially treated sewage.	Moderate	Rare	Inappropriate work practices and carelessness.	Low
<b>Public Contact With Pollutants</b>					
	Public coming into contact with raw sewage or treated effluent.	Moderate	Rare	Poor site management and supervision.	Low





### 3.0 Pre-Emptive Actions to Minimise Risk to Human Health or the Environment

Council undertakes a number of pre-emptive actions to minimise risk to human health and the environment. These are described below:

#### 1. Effluent and Sewage Overflows

Wet weather and dry weather overflows from the sewerage reticulation system are low risk events as determined in the Risk Assessment (Table 1 above).

Staff maintain the system on a daily basis and all blockages in the system are cleared promptly.

In times of high wet weather flows, there is the potential for the capacity of the treatment plant to be exceeded, resulting in overflows. This is considered unlikely, with a medium overall risk rating (refer Table 1 above). Influent can be diverted directly to the storage lagoons in the event of extreme wet weather events.

Pond failure is an extremely unlikely event. The storages are regularly inspected to ensure there are no leaks and staff maintains all facilities at the Henty STP on a daily basis.

Mechanical failure at the Henty STP has been assessed as a medium overall risk (refer Table 1 above). Independent assessment of the plant is carried out every five years as part of the mandatory asset valuation process. Any structural issues can be actioned at that time. Plant operators are fully trained and they inspect and monitor the plant daily.

Flooding of the process units or storage ponds is a low risk hazard. The State Emergency Service has Emergency Management Plans in place to warn of any impending flood. The dilution level of any overflow during an extreme event will significantly reduce the impact of any pollutants released.

#### 2. Odours

The risk of odours resulting from mechanical failure of plant and equipment or uncontrolled release of gases have been assessed as medium risk events. Council staff maintain all plant and equipment at the Henty STP on a continuous basis and any faulty equipment is either repaired or replaced.

Process failures are mitigated by the on-going monitoring of the plant by Council's trained operators.

#### 3. Storage of Chemicals

The only chemicals stored at the Henty STP are used to disinfect the effluent prior to reuse. The Site Plan (included as Appendix E) shows where these chemicals are stored on site. Material Data Safety Sheets and Safe Work Method Statements are kept on site for handling these chemicals. Only appropriately trained suppliers are employed by Council to transport the chemicals to site.

#### 4. Vandalism

The Henty STP is securely fenced and is patrolled by Council staff.

## 5. Pipe And Structural Failures

An independent assessment of Council's assets is carried out every five years as part of the mandatory asset valuation process. Any issues with pipes, pump stations and other infrastructure can be actioned at that time. Council's maintenance staff are fully trained and they regularly inspect all sewerage infrastructure.

## 6. Licence Exceedence

On-going monitoring of the treatment processes and sampling and testing of effluent mitigate the risks associated with licence exceedence. If any testing indicates an exceedence, irrigation of effluent would cease until the problem with the treatment plant was corrected.

## 7. Irrigation Activities

On-going monitoring of the treatment processes and sampling and testing of effluent mitigate the risks associated with reuse of effluent at the nominated irrigation sites (the Billabong High School oval and gardens and the Henty Recreation Ground). If any testing indicates an exceedence, irrigation of effluent would cease until the problem with the treatment process was corrected.

## 8. Sludge Handling

All sewage sludge is stored and disposed of on site, thus minimising the risk of contaminants moving off site.

## 9. Trade Waste

Council has a Trade Waste Policy in place which prevents the discharge of:

- organochlorine weedicides, fungicides, pesticides, herbicides and substances of a similar nature
- organophosphorus pesticides and/or waste arising from the preparation of these substances
- any substances liable to produce noxious or poisonous vapours in the sewerage system
- radioactive substances
- organic solvents and mineral oil
- any flammable or explosive substance
- chromate from cooling towers
- natural or synthetic resins, plastic monomers, synthetic adhesives, rubber and plastic emulsions
- rain, surface, seepage or subsoil water
- solid matter
- any substance assessed as not suitable to be discharged into the sewerage system
- waste that contains pollutants at concentrations which inhibit the sewage treatment process.

## 10. Personnel Coming Into Contact With Raw Sewage

Council has in place Work Place Health and Safety documentation at the Henty STP and staff are trained in all aspects of workplace health and safety.

Treatment plant operators are required to have designated inoculations to protect them.

There is no public access to the Henty STP.

Site visitors are given the appropriate induction before proceeding on a tour of the plant and care is taken by staff to ensure that they are not exposed to any risk of contact with the raw sewage or treated effluent.

## 11. Public Contact With Raw Sewage or Treated Effluent

Treated effluent is utilised at the wetlands and at the two irrigation sites.

Irrigation of the effluent is controlled by Council's Site Management Plan which restricts public access to the sites during irrigation and for a period after irrigation ceases.

Access to the wetlands is also restricted and the precautions discussed in point 10. above apply.

## 4.0 Inventory of Pollutants and Details of Storage Locations

### 1. Chemicals

The only chemicals used at the Henty STP are Hydrochloric Acid and Sodium Hypochlorite (for disinfection of effluent prior to irrigation reuse), which are stored in a secure shed on site, as shown on the Site Plan in Appendix E.

### 2. Sewage Effluent

Treated effluent is stored at the Henty STP at the following locations:

- a) the maturation storage lagoon (effluent pond)
- b) the 30ML reuse storage dam
- c) the wetlands.

Raw sewage passes through the treatment process with minimum storage time.



## 5.0 Description of Safety Equipment or Other Devices Used to Minimise Risk and To Control a Pollution Incident

The Henty STP building is protected from fire by fire extinguishers.

Personal protective equipment (PPE) is provided for on-site staff which consists of overalls, rubber boots, chemical goggles, face shields, safety shoes, elbow-length impervious gloves, splash aprons and air supplied respirators.



## 6.0 Contact Details

### 6.1 Definition of Pollution Incident

A pollution incident is required to be notified if there is a risk of 'material harm to the environment', which is defined in section 147 of the POEO Act 1997:

- a) *harm to the environment is material if:*
  - I. *it involves actual or potential harm to the health or safety of human beings or to ecosystems that is not trivial, or*
  - II. *it results in actual or potential loss or property damage of an amount, or amounts in aggregate, exceeding \$10,000, and*
- b) *loss includes the reasonable costs and expenses that would be incurred in taking all reasonable and practicable measures to prevent, mitigate or make good harm to the environment."*

### 6.2 Notification of Pollution Incident

#### **Notification Speed of Response**

The requirement for notification of a pollution incident has changed from 'as soon as practicable' to 'immediately'. In short, 'immediately' means 'promptly without delay', but it does not mean undertaking notification ahead of doing what is necessary to make safe.

#### **Notification of Relevant Authorities**

If the pollution incident is a wet weather overflow, dry weather overflow, wet weather bypass or dry weather bypass procedures need to be followed in Council's *PRP 101 Incident Notification Protocol, August 2012*.

In all other pollution incident cases and where the pollution incident causes or threatens material harm to the environment or human health, all the following authorities must be notified by the Site Supervisor:

## Relevant Authorities to be Notified

1. Emergency Call Services
  - Emergency Hotline Number (24 hours) 000\*

**\*The Site Supervisor should call 000 if the incident presents an immediate threat to human health and/or property and a combat agency is required (i.e. NSW Fire and Rescue, NSW Ambulance Service, NSW Police Force), and then notify all other parties below including NSW Fire and Rescue via a local telephone number.**

2. Greater Hume Council
  - Water and Sewerage On-call 0408 691 637
3. The Environment Protection Authority (EPA)
  - EPA 24hr Environment Line 131 555
  - Albury Regional Office 02 6022 0600
4. NSW Ministry of Health (via Public Health Units)
  - Albury Regional Office 02 6841 5569
  - Public Health Officer on Call (24 hours) 0418 866 397
5. WorkCover NSW
  - Hotline Number 131 050
6. Fire and Rescue NSW
  - Henty Fire Brigade 02 6029 8202
  - Rural Fire Service Control Centre 02 6051 1511
7. SES Henty 02 6029 8866

If there is no immediate threat to human health and/or property i.e. a combat agency is not required, then the Site Supervisor is still required to contact the above except for dialling 000.

Key Council staff contact details are listed in Table 2 on page 16.

Table 2: Key Council Staff Contact Details

Name	Job Title	Contact No.	Qualification/Competencies
Ben Falconer	Manager Water and Waste Water	0418 770 635	BE Civil Cert III Water Industry Operations Water, Wastewater and Networks Cert III Liquid Trade Waste Regulation
Paul Day	Water and Waste Water Overseer	0458 058 389	Part 1. Waste Water Treatment Operations (OOW) In training Part 2. Advanced Treatment (OOW) In training Confined Space Entry.
Jeremy Head	Water and Waste Water Operator	0407 018 572	Part 1. Waste Water Treatment Operations (OOW) Part 2. Advanced Treatment (OOW) In training Confined Space Entry Chemical Handling.
Tim Robinson	Water and Waste Water Operator	0417 487 899	Part 1. Waste Water Treatment Operations (OOW) In training Part 2. Advanced Treatment (OOW) In training Confined Space Entry Chemical Handling.
Jason Hulm1	Water and Waste Water Operator	0417 487 899	Part 1. Waste Water Treatment Operations (OOW) Part 2. Advanced Treatment (OOW) Confined Space Entry Chemical Handling.
Colin Summers	Water and Waste Water Operator	0429 076 196	Certificate 111 in Waste Water Operations (NRT) Part 2. Advanced Treatment (OOW) Confined Space Entry Chemical Handling.
Ethan Davies	Water and Waste Water Operator	0427 206 389	Cert III Water Industry Operations Water, Wastewater and Networks Confined Space Entry Chemical Handling.
Emergency On Call Phone	Water and Waste Water Operators	0408 691 637	N/A

**6.3 List of Those Authorised To Notify Relevant Authorities Under Section 148 Of POEO Act**

<b>Name</b>	<b>Position</b>	<b>Mobile No. (First point of contact)</b>	<b>Landline Second point of contact</b>
Greg Blackie	Director Engineering	0419 249 357	02 6036 0142
Ben Falconer	Manager Water and Waste Water	0418 770 635	02 6036 0100



## 7.0 Communication with Neighbours and Local Community

### Figure 2 (below)

Shows the location of surrounding and adjacent residents and their proximity to the Henty STP (*nearest properties are identified by a house symbol*).

The procedure for providing early warnings and regular updates to the owners and occupiers of premises which may be affected by an incident is:

#### STEP 1:

Once the EPA is notified, it is then for the EPA to determine whether commercial, industrial and residential neighbours of the site need to be contacted by Council and informed of the circumstances of the incident and what action is being taken in response to it. If deemed necessary, the EPA then has powers to formally direct Council to notify the neighbours of the site.

Irrespective of whether the EPA directs Council to notify neighbours and depending on the circumstances of the particular pollution incident, Council may at their own discretion voluntarily choose to notify neighbours.

#### STEP 2:

The first step in contacting neighbours is to telephone or doorknock any area that may be impacted by an incident. In the case of a plant failure, the impacted area would include all downstream users of the water source.


In the case of an odour issue, the affected area would include all adjacent and surrounding properties.

#### STEP 3:

If wider communication is required with the local community, this will be achieved through local radio stations (ACE Radio 2AY, Star FM The River, ABC Goulburn Murray) and Council's website ([www.greaterhume.nsw.gov.au](http://www.greaterhume.nsw.gov.au)).

Location of the Henty STP and proximity to residents is shown in Figure 2 on page 18.

Figure 2: Location of Henty STP and Proximity to Residences





## 8.0 Arrangements to Minimise Risk of Harm to Persons on the Premises Should an Incident Occur

In the event of a pollution incident occurring, all site contractors and other Council staff will be mustered by Council site staff to the Emergency Assembly Point adjacent to the site entrance, after which they will be safely evacuated from site where appropriate. It is a condition of entry that in the event of an emergency, both site contractors and staff must adhere to directions given by the Site Supervisor.

Figure 3: Photos of Signage to Warn the Public of Hazards



## **9.0 Actions to be Taken During or Immediately After a Pollution Incident, Including Early Warnings, Updates and Actions to be Undertaken by the Media**

### **Actions to be taken during or immediately after a pollution incident include:**

- I. Isolate the source of pollution, wherever possible.
- II. In the event of an overflow situation, effluent can be diverted directly from the inlet works to the effluent reuse storage dam and/or the wetlands. The effluent would be highly diluted, thereby minimising risks.
- III. Notify the manager Water and Waste Water.
- IV. Continue to isolate the pollution wherever possible.
- V. Notify the relevant Statutory Authorities listed under Section 6.2 above.
- VI. Communicate with affected neighbours and the community, as required, in accordance with Section 7 above.
- VII. Implement remedial action, as appropriate and as required by the EPA.
- VIII. Complete and submit Incident Reporting Form (as included in Appendix B).

## 10.0 Staff Training

All Henty STP operators are skilled and fully trained.

Qualifications are all current and staff training records are maintained by Council's Human Resources Officer and are available in the corporate data base.

All existing Henty STP staff will be required to read and to sign to the effect that they have read and understand this PIRMP.

New members of staff at the facility should be inducted. This induction must cover the purpose, requirements and responsibilities detailed in this PIRMP.

All staff should receive sufficient training to enable them to carry out their assigned duties in a competent and safe manner.

In particular:

- staff must be capable of using the fire-fighting equipment
- staff must be capable of identifying potential pollution incidents; and
- staff must be familiar with the requirements and procedures contained within this PIRMP.

Staff competency will be monitored through audits, public complaints and pollution incident reports.

At least once every year staff should undertake a simulated pollution incident response exercise, including with emergency services, to familiarise site personnel with the requirements of this management plan. A register of staff training can be found in Appendix D which must be kept on site and updated regularly.

Regular site briefings and toolbox meetings should be held when considered appropriate to draw attention to potential pollution incidents and identify improvements to on-site safety procedures.

## 11.0 Making Plans Available

A copy of this PIRMP will be available at the Henty STP and will be available on Council's website:

[www.greaterhume.nsw.gov.au/councilservices/watersewerage/tabid/128/default.aspx](http://www.greaterhume.nsw.gov.au/councilservices/watersewerage/tabid/128/default.aspx)



## 12.0 Testing Plans Once Every 12 Months

The PIRMP is a living document required to be reviewed and updated at least once every 12 months to ensure accuracy and effectiveness. A review must also be undertaken within one month of any pollution incident occurring.

For these reasons, document control is an important part of the environmental management system. It is critical that PIRMP storage locations are made known to all relevant staff members and that only the latest version is in use. Details of the version and date of issue are recorded on each page of the PIRMP in the bottom left hand corner.

Revised and updated versions of the PIRMP will always be issued with a covering memo summarising the changes. When a new PIRMP is received, the old version will be replaced in its entirety. A register for updating and testing the PIRMP can be found in Appendix C and must be kept on site and updated regularly.

Copies of the revised PIRMP will be distributed to all relevant staff.

Testing of the PIRMP will be implemented by Council, involving a desktop test of the plan involving all Henty STP staff.

## 13.0 Appendices

### 13.1 Appendix A: Risk Assessment Matrix

#### Risk Assessment and Management - Methodology

Risk Assessment has been carried out using the following Framework and Matrix

Table 1: Determination of Risk Likelihood

Rating	Descriptor	Description
1	Rare	The event may occur only in exceptional circumstances – for example 1 in 100 years or greater.
2	Unlikely	The event could occur at some time but is not usually experienced – for example 1 in 30 years.
3	Possible	The event might occur at some time over a 4-10 year period.
4	Likely	The event will probably occur at least once every 1-3 years.
5	Almost Certain	The event is expected to occur in most circumstances or at least once a year.



Table 2: Determination of Risk Consequence

Rating	Classification	Operations		Stakeholders		Environment
		Health and Safety	Operations	Service Delivery	Stakeholder and Legal	Environmental impact
1	Insignificant	No injuries (includes minor scratches and abrasions and bruises) or impact on public health.	Consequences are dealt with by routine operations, corrective action.	Negligible impact on service delivery.	Stakeholder indifference. No legal significance.	Insignificant impact on the environment (no lasting effect, limited damage to minimum area of low significance).
2	Minor	Minor injuries requiring first aid or public health impacts.	Consequences could threaten the efficiency or effectiveness of some aspects of operations. No loss of production or services.	Minor corrective action required to restore service delivery for local customers.	Stakeholder aware of issue. Minor legal and non-compliance issues remedied by prompt attention.	Minimal impact on environment (contained on site and or minor short/medium term damage to small area of small significance).
3	Moderate	Medical treatment required (workforce) or minor public health impact.	Consequences would lead to a review and changed ways of operating. Significant loss of production or service.	Service restored after major intervention but within performance indicator levels.	Stakeholder actively expressing dissatisfaction Moderate breach of policy or regulation leading to low level investigation or penalties.	Off-site environmental impacts or community interest in impacts. Moderate short/medium term widespread impacts.
4	Major	Extensive injuries, sickness or alarm for public health.	Consequences would lead to a significant review and changed ways of operating. Serious loss of production or services.	Service delivery interrupted failing performance indicators. Could be recurring in nature.	Stakeholder alarm or grave concern. Serious breach of policy or regulation and exposure to court imposed penalties.	Environmental damage with legal action likely. Serious widespread medium/long term impacts.
5	Catastrophic	Major injury or death of worker or public.	Consequences would result in a significant review and changed ways of operating. Major loss of production or services.	Major failure to service delivery and considerable time to restore. Could be ongoing in nature.	Enraged stakeholder or external intervention ordered by government. Serious litigation with prosecution and serious penalties.	Extreme environmental event with prosecution certain. Very serious long term effects on a significant environment.

Table 3: Determination of Overall Inherent Risk Rating Using Risk Matrix

	Consequence				
Likelihood	Insignificant 1	Minor 2	Moderate 3	Major 4	Catastrophic 5
Almost Certain 5	High	High	Extreme	Extreme	Extreme
Likely 4	Medium	High	High	Extreme	Extreme
Possible 3	Low	Medium	High	High	Extreme
Unlikely 2	Low	Low	Medium	High	High
Rare 1	Low	Low	Low	Medium	High

1	Low
2	Low
3	Low
4	Low
5	Medium
6	High
7	High
8	Extreme
9	Extreme
10	Extreme

### 13.2 Appendix B: Pollution Incident Reporting Form

Pollution Incident Reporting Form			
Incident No:		Time:	
Date:		Duration of Incident:	
<b>Nature of Incident:</b>			
<b>Weather Conditions:</b>			
<b>The Location of the Place Where Pollution is Occurring or is Likely to Occur:</b>			
<b>The Nature, the Estimated Quantity or Volume and the Concentration of any Pollutants Involved (if known):</b>			
<b>The Circumstances in Which the Incident Occurred, Including the Cause of the Incident (if known):</b>			

**Pollution Incident Reporting Form**

**The Corrective Action Taken or Proposed to be Taken to Deal with the Incident and Any Resulting Pollution or Threatened Pollution (if known):**


Has Council Been Notified?	Yes	No
Has Environment Protection Authority (EPA) Been Notified	Yes	No
Has NSW Ministry of Health (via Public Health Units) Been Notified?	Yes	No
Has WorkCover NSW Been Notified?	Yes	No
Has Local Fire and Rescue NSW Been Notified?	Yes	No
Has EPA Directed Council to Notify Neighbours?	Yes	No
If Not, Has Council Voluntarily Notified Neighbours?	Yes	No

<b>Signature</b> .....	<b>Date</b> .....
<b>Site Supervisor, Greater Hume Council</b>	
<b>Signature</b> .....	<b>Date</b> .....
<b>Water Operations Engineer, Greater Hume Council</b>	

### 13.4 Appendix C: PIRMP Testing and Update Register


PIRMP Testing and Update Register				
Date	Routine testing	Routine Update	Post incident Updates	New Copies Distributed to:
29/10/2013	Completed	N/A	N/A	N/A
30/10/2014	Completed	N/A	N/A	N/A
11/05/2015	Completed	N/A	N/A	N/A
18/07/2016	Completed	N/A	N/A	N/A
4/01/2017	N/A	Yes. Update Key Council Staff Contacts	N/A	To Key Council Staff & Premises s
17/01/2017	Completed	N/A	N/A	N/A
14/08/2017	Completed	N/A	N/A	N/A
19/09/2018	Completed	N/A	N/A	N/A
1/12/2018	N/A	Updated to reflect New Council Branding and Position Titles	N/A	To Key Council Staff & Premises
18/9/2019	Completed	N/A	N/A	N/A
16/3/2020	Completed	N/A	N/A	N/A
13/4/21	Completed	N/A	N/A	N/A
26/06/2024	Completed	Updated key Council Staff Contacts	N/A	To Key Council Staff & Premises. Updated Documents uploaded to website

### 13.5 Appendix D: Staff Training Register

Staff Training Register		
Date	Staff Member	Brief Description Of Training Task
4/05/2015	Colin Summers	Wastewater – Update Seminar
12/08/2015	Jeremy Head	Confined Space Training
10/09/2015	Colin Summers	Confined Space Training
10/09/2015	Mark Nichols	Confined Space Training
12/11/2015	Tom Plunkett	Confined Space Training
14/03/2016	Jeremy Head	Wastewater Course Part 1
25/07/2016	Paul Day	Confined Space Training
17/10/2016	Trent Brown	Confined Space Training
5/10/2017	Mark Nichols	Confined Space Training
5/10/2018	Colin Summers	Confined Space Training
30/08/2018	Paul Day	Confined Space Training
31/08/2018	Jeremy Head	Confined Space Training
27/09/2018	Trent Brown	Confined Space Training
11/7/2019	Jeremy Head	Confined Space Training
11/7/2019	Paul Day	Confined Space Training
8/8/2019	Trent Brown	Confined Space Training
8/8/2019	Mark Nichols	Confined Space Training
8/8/2019	Colin Summers	Confined Space Training
21/6/2023	Colin Summers	Confined Space Training
21/6/2023	Paul Day	Confined Space Training
21/6/2023	Jeremy Head	Confined Space Training
21/6/2023	Tim Robinson	Confined Space Training
21/6/2023	Jason Hulm	Confined Space Training
21/6/2023	Ethan Davies	Confined Space Training



13.6 Appendix E: Site Plan



Greater Hume Shire Council – Pollution Incident Response Management Plan – Henty Sewage Treatment Plant





Greater  
Hume  
Council



# Pollution Incident Response Management Plan

## Henty Sewage Treatment Plant

[greaterhume.nsw.gov.au](http://greaterhume.nsw.gov.au)