


**POLLUTION MONITORING DATA
CULCAIRN SEWAGE TREATMENT WORKS**



Environment Protection Licence No.: 3727

Link to full licence on EPA website:

<http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=33959&SYSUID=1&LICID=3727>

Licensee: Greater Hume Shire Council, PO Box 99 Holbrook NSW 2644

Address of facility: Cemetery Road, Culcairn NSW 2660

Monitoring Point 3

Location: Sampling point prior to discharge from effluent pond 2

Published: Decemeber 2021

Obtained: 23 Nov 2021

Sampled: 9 Nov 2021

| Pollutant | Unit | Frequency | Measurement | 100 percentile limit | Exceedence (yes/no) | Comments |
|---------------------------|-----------|-----------|-------------|----------------------|---------------------|---------------------------------------|
| Biochemical oxygen demand | mg/l | Quarterly | 5 | 20 | no | |
| Chlorophyll-a | ug/L | Quarterly | 5 | | | |
| Conductivity | ms/cm | Quarterly | 820 | | | |
| Faecal Coliforms | cfu/100ml | Quarterly | <1 | | no | |
| Nitrogen (total) | mg/l | Quarterly | 1.3 | 20 | no | |
| Oil and Grease | mg/l | Quarterly | <2 | 10 | no | |
| pH | | Quarterly | 10.5 | | | |
| Phosphorus (total) | mg/l | Quarterly | 0.8 | 10 | no | |
| Total suspended solids | mg/l | Quarterly | 8 | 30 | no | As per Licence condition L2.5 (a) (b) |