


**POLLUTION MONITORING DATA
HENTY SEWAGE TREATMENT WORKS**



Environment Protection Licence No.: 3726

Link to full licence on EPA website:

<http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=33963&SYSUID=1&LICID=3726>

Licensee: Greater Hume Shire Council, PO Box 99 Holbrook NSW 2644

Address of facility: Comer Street, Henty NSW 2658

Monitoring Point 1

Location: Sampling point prior to discharge from effluent pond 1

Published: 22 May 2018

Obtained: 20 Feb 2018

Sampled: 7 Feb 2018

Pollutant	Unit	Frequency	Measurement	100 percentile limit	Exceedence (yes/no)	Comments
Biochemical oxygen demand	mg/l	Quarterly	11	20	no	
Chlorophyll-a	ug/L	Quarterly	18			
Conductivity	ms/cm	Quarterly	680			
Faecal Coliforms	cfu/100ml	Quarterly	2400		no	
Nitrogen (total)	mg/l	Quarterly	1.7	20	no	
Oil and Grease	mg/l	Quarterly	<2	10	no	
pH		Quarterly	7.1			
Phosphorus (total)	mg/l	Quarterly	6.8	10	no	
Total suspended solids	mg/l	Quarterly	2	30	no	As per Licence condition L2.5 (a) (b)