

POLLUTION MONITORING DATA HOLBROOK SEWAGE TREATMENT WORKS



Environment Protection Licence No.: 1804

Link to full licence on EPA website:

<http://www.epa.nsw.gov.au/prpoeoapp/ViewPOELicence.aspx?DOCID=33960&SYSUID=1&LICID=1804>

Licensee: Greater Hume Shire Council, PO Box 99 Holbrook NSW 2644

Address of facility: Bath Street, Holbrook NSW 2644

Monitoring Point 4 (Representative sample for monitoring points 1 & 2)

Location: Sampling point prior to discharge from effluent tertiary pond

Published: 22 July 2016

Obtained: 21 Aug 2015

Sampled: 11 Aug 2015

Pollutant	Unit	Frequency	Measurement	100 percentile limit	Exceedence (yes/no)	Comments
Biochemical oxygen demand	mg/l	Quarterly	5	20	no	
Chlorophyll-a	ug/L	Quarterly	6			
Conductivity	ms/cm	Quarterly	870			
Faecal Coliforms	cfu/100ml	Quarterly	1300			
Nitrogen (total)	mg/l	Quarterly	24			
Oil and Grease	mg/l	Quarterly	<2	10	no	
pH		Quarterly	8			
Phosphorus (total)	mg/l	Quarterly	5.2			
Total suspended solids	mg/l	Quarterly	8	30	no	As per Licence condition L2.6 (a) (b)