

# POLLUTION MONITORING DATA

## HOLBROOK SEWAGE TREATMENT WORKS



**Environment Protection Licence No.:** 1804

Link to full licence on EPA website:

<http://www.epa.nsw.gov.au/prpoeoapp/ViewPOELicence.aspx?DOCID=33960&SYSUID=1&LICID=1804>

**Licensee:** Greater Hume Shire Council, PO Box 99 Holbrook NSW 2644

**Address of facility:** Bath Street, Holbrook NSW 2644

### Monitoring Point 4 (Representative sample for monitoring points 1 & 2)

**Location:** Sampling point prior to discharge from effluent tertiary pond

**Published:** 10 July 2014

**Obtained:** 20 Feb 2014

**Sampled:** 11 Feb 2014

Pollutant	Unit	Frequency	Measurement	100 percentile limit	Exceedence (yes/no)	Comments
Biochemical oxygen demand	mg/l	Quarterly	15	20	no	
Chlorophyll-a	ug/L	Quarterly	290			
Conductivity	ms/cm	Quarterly	840			
Faecal Coliforms	cfu/100ml	Quarterly	17000			
Nitrogen (total)	mg/l	Quarterly	4.6			
Oil and Grease	mg/l	Quarterly	<2	10	no	
pH		Quarterly	9.4			
Phosphorus (total)	mg/l	Quarterly	4.8			
Total suspended solids	mg/l	Quarterly	30	30	no	