

## POLLUTION MONITORING DATA HOLBROOK SEWAGE TREATMENT WORKS



**Environment Protection Licence No.:** 1804

Link to full licence on EPA website:

<http://www.environment.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=31289&SYSUID=1&LICID=1804>

**Licensee:** Greater Hume Shire Council, PO Box 99 Holbrook NSW 2644

**Address of facility:** Bath Street, Holbrook NSW 2644

### Monitoring Point 3

**Location:** Flow meter at the inlet to Sewage Treatment Plant

**Published:** 22 June 2012

**Obtained:** 1 June 2012

**Sampled:** From 1 July 2011 to 31 May 2012

Item	Unit	Frequency	Lowest result	Mean result	Max result	Volume limit	Exceedence (yes/no)	Comments
Daily flow	kl/day	Daily	322	428	1620	500	Under review	Wet weather event

### Monitoring Point 4 (Representative sample for monitoring points 1 & 2)

**Location:** Sampling point prior to discharge from effluent tertiary pond

**Published:** 22 June 2012

**Obtained:** 28 May 2012

**Sampled:** 16 May 2012

Pollutant	Unit	Frequency	Measurement	100 percentile limit	Exceedence (yes/no)	Comments
Biochemical oxygen demand	mg/l	Quarterly	12	20	no	
Chlorophyll-a	ug/L	Quarterly	39			
Conductivity	ms/cm	Quarterly	910			
Faecal Coliforms	cfu/100ml	Quarterly	3800			
Nitrogen (total)	mg/l	Quarterly	23			
Oil and Grease	mg/l	Quarterly	<2	10	no	
pH		Quarterly	7.9			
Phosphorus (total)	mg/l	Quarterly	6.1			
Total suspended solids	mg/l	Quarterly	7	30	no	