

POLLUTION MONITORING DATA HOLBROOK SEWAGE TREATMENT WORKS



Environment Protection Licence No.: 1804

Link to full licence on EPA website:

<http://www.epa.nsw.gov.au/prpoeoapp/ViewPOELicence.aspx?DOCID=33960&SYSUID=1&LICID=1804>

Licensee: Greater Hume Shire Council, PO Box 99 Holbrook NSW 2644

Address of facility: Bath Street, Holbrook NSW 2644

Monitoring Point 4 (Representative sample for monitoring points 1 & 2)

Location: Sampling point prior to discharge from effluent tertiary pond

Published: June 2019

Obtained: 26 Feb 2019

Sampled: 6 Feb 2019

Pollutant	Unit	Frequency	Measurement	100 percentile limit	Exceedence (yes/no)	Comments
Biochemical oxygen demand	mg/l	Quarterly	20	20	no	As per Licence condition L2.6 (a) (b)
Chlorophyll-a	ug/L	Quarterly	180			
Conductivity	ms/cm	Quarterly	1000			
Faecal Coliforms	cfu/100ml	Quarterly	4600			
Nitrogen (total)	mg/l	Quarterly	8.2			
Oil and Grease	mg/l	Quarterly	<2	10	no	
pH		Quarterly	8.4			
Phosphorus (total)	mg/l	Quarterly	8.2			
Total suspended solids	mg/l	Quarterly	26	30	no	As per Licence condition L2.6 (a) (b)